

INTRODUCTION

This report is the twenty-fifth Annual Water Quality Report of the Belfast Water District serving Belfast and provides essential information about your drinking water. We know that you count on us for a safe and reliable supply of water every day and our dedication to providing the highest quality of service to you at a great value. You may be interested to know that you pay less than one cent per gallon of water at the minimum rate. Water delivered to your home, you get 2 gallons for 1.5 cents, ten gallons for 7.5 cents, and 100 gallons for 75 cents. This water supply has been tested for hardness 68 mg/l = 3.97 grains per gallon, considered 'moderately' hard.

THE CONTENTS OF THIS REPORT

The Safe Drinking Water Act mandates the State of Maine and the Environmental Protection Agency (EPA) to establish and enforce minimum drinking water standards. These standards limit certain biological, radioactive, organic, and inorganic substances sometimes found in drinking water. The limits set on these standards are known as MCLs, Maximum Contaminant Levels. There are two types of standards established. Primary Standards set achievable levels of drinking water quality to protect your health. Secondary Standards provide guidelines regarding your drinking water's taste, odor, color, and other aesthetic aspects, which do not present a health risk. This report lists the results of the system's regular testing, which provides the test results for both Primary and Secondary Standards.

The 2022 test results indicate *Belfast Water District's system* meets all state and federal requirements. **No violations occurred in 2022.** The water is tested for the contaminants listed in the table. The data presented in this report are from the most recent testing done per the regulations set forth by the Safe Drinking Water Act.

WATER QUALITY

We ensure that your water is safe through regular monitoring and testing of water quality. Maine State Health and Environmental Testing Laboratory and Maine Water Testing Laboratory conduct these tests, State certified testing laboratories. This report comprehensively summarizes the laboratory test results for the constituents we regularly monitor in your water supply. Responsibility for maintaining water quality resides with our staff of certified water treatment plant operators licensed by the State of Maine Department of Human Services.

HEALTH INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Contaminants that may be present in source water include:

Microbial, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. **Inorganic chemicals**, such as salts and metals, which can naturally occur or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. **Pesticides and Herbicides**, which may come from various sources, such as agriculture, urban stormwater runoff, and residential uses. **Organic chemicals**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems. **Radioactive Contaminants**, which can naturally occur or result from oil and gas production and mining activities. However, some people may be more vulnerable to contaminants in drinking

water than the general population. Immunocompromised persons such as those with cancer undergoing chemotherapy, who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at the following link: <https://www.epa.gov/ccr/forms/contact-us-about-consumer-confidence-reports>

MCL's (maximum contaminant levels) are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters (or about 2 quarts) of water daily at the MCL level for a lifetime to have a one in ten thousand chance of having the described health effect.

LEAD AND COPPER

The Federal Lead and Copper Rule mandates household testing for Lead and Copper. According to the rule, 90% of the home samples must have lead levels less than 15 ppb and Copper levels less than 1.3 ppm. If present, elevated lead levels can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Belfast Water District is responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead, you should have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water link: <http://www.epa.gov/safewater/lead>

RADON

The highest Radon levels for our system were 969 pCi/L, taken in June 2005. Radon is found in the soil and bedrock formations and is a water-soluble, gaseous by-product of Uranium. Most Radon is released into the air moments after turning on the tap. Only about 1-2 percent of Radon in the air comes from drinking water. The U.S. EPA is considering setting lower standards for Radon in drinking water. The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4,000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. The U.S. EPA proposes setting federal standards for Radon in public drinking water. It is also advisable to test indoor air for Radon. Breathing Radon released into the air from tap water increases the risk of lung cancer over the course of your lifetime. For information about Radon, contact our office or the Maine Drinking Water Program and request a Radon Fact Sheet.

TESTING WAIVER GRANTED

In 2020, our system was granted a 'Synthetic Organics Waiver'. This waiver is a three-year exemption from the monitoring and reporting requirements due to the absence of the potential sources of contamination within a half-mile radius of the water source(s) for the following industrial chemical(s): TOXAPHENE/CHLORDANE/PCB, HERBICIDES, CARBAMATE PESTICIDES, and SEMIVOLATILE ORGANICS.

WATER SUPPLY/SOURCE INFORMATION

The Belfast Water District uses groundwater as its water source. Two gravel-packed wells are located in the Goose River Aquifer in Swanville and Belfast. These wells have been in production since the 1950s and provide a reliable supply source. The wells are protected by the Aquifer/Watershed Overlay District Ordinance adopted by the City of Belfast in 1990.

WATER TREATMENT AND ASSESSMENT

This water utility uses three treatment techniques to ensure water quality. They include Sodium Hydroxide for corrosion control, Fluoride for the reduction of tooth decay, and Sodium Hypochlorite for disinfection.

Sodium Hydroxide, for the control of Lead and Copper. Maintaining the proper pH with the addition of sodium hydroxide, 25% solution in the water, protects our distribution system and your home's plumbing system from the effects of lead and copper. The Federal EPA Standard for Lead is 15 ppb or less, and copper is 1.3 ppm or less. This treatment has been so effective that our annual monitoring program for lead and copper levels has been reduced to once every three years under EPA guidelines. In August 2020, Belfast Water tested 20 sites in the distribution system. **Results:** Lead – 4.26 ppb and copper – 0.185 ppm. (0 sites failed out of the 20 tested). **Our next testing will be in the summer of 2023.**

Sodium Fluoride, Fluoridation was authorized by referendum ballot on March 14, 1960, by the citizens of Belfast to reduce tooth decay. The Belfast Water District adds Sodium Fluoride to the water at the EPA-recommended rate of 0.70mg/l.

Sodium Hypochlorite is added to ensure adequate water disinfection has occurred before delivery to you. Per EPA guidelines, Belfast Water has a disinfection level between 0.20 mg/l – 0.40 mg/l in the entire system. Monthly bacteria samples are taken at six sites in the water system, and test results are reported to the Maine Drinking Water Program. Of the 72 samples taken in 2022, 0 failed.

MONITORING AND TESTING

Belfast Water District has four Maine State licensed operators that monitor and test your water. Analyzers continuously monitor the treatment levels at both wells, and SCADA records all information. The operators are notified immediately by the SCADA of any variances and immediately respond to correct them. These operators also perform backup tests of the water daily and weekly.

SOURCE WATER ASSESSMENT AND PROTECTION

Drinking water sources include rivers, lakes, ponds, and wells. As water travels over the land's surface or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of our land ownership or protection by local ordinances to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices and public water systems. Our wells are rated as a moderate risk because they are gravel-packed wells installed in a surficial aquifer. The current land use around our wells results in a low risk for bacteria and nitrates and a low to moderate risk for long-term, chronic contaminants. Both wells are isolated from most sources of potential contamination. Our extensive property ownership and wellhead

protection program, including a local ordinance, indicate a low future risk for bacterial contamination and a low to moderate risk for chronic contaminants. These are essential features in providing long-term protection. We will continue to work with the City of Belfast to maintain and support these programs.

For more information, contact:
the Maine Drinking Water Program at 287-2070.

WATER SYSTEM DATA

Your water supply and distribution system include over 39 miles of water mains. The system has 2,064 services serving 5,160 customers in 2022 and provides fire protection service through 256 hydrants. We have produced and delivered over 192,958,700 gallons of water in the last twelve months. That's an average of 528,867 gallons each day. The system also maintains 3,050,000 gallons of water in our four storage tanks, allowing us to meet peak system demand periods and maintain an adequate supply during firefighting activities.

OTHER IMPORTANT INFORMATION

This report summarizes our activities during the past year. If you have any questions about your water quality, the information contained in this report, or your water service in general, please call us at our office (207) 338-1200, Monday thru Friday, 7:00 AM-3:30 PM, or contact us by e-mail at: info@belfastwater.org or fax (207) 338-0444.

The Belfast Water District moved its facilities from 285 Northport Avenue to 41 Wight Street in November 2022. The Belfast Water District's Board of Trustees and Employees look forward to providing outstanding service to its customers and the general public from our new location.

Board of Trustees meetings are held monthly and open to the public. For upcoming meetings, please visit our website under the Notices tab – Board of Trustees Meetings at:
<http://www.belfastwater.org/meetingdate.htm>

BOARD OF TRUSTEES

Bruce Osgood – *Chairman*
Kenneth Colby Horne – *Vice Chairman*
Stephen Hall, *Treasurer*
Jill Goodwin, *Secretary/Clerk*
Chad Otis, *Trustee*

EMPLOYEES

Frank Short, *Superintendent*
Keith Pooler-*Superintendent (Retired 2-28-23)*
Tammy Morse-*Administrator*
Suzette Harford-*Accounts Manager*

Plant Operations and Distribution

Dustin Howes, *Foreman*
Donald Hahn
Hayden Bradford
Zechariah Harriman

Thank you for allowing us to continue
to provide you with clean, quality water this year!

Primary Drinking Water Standards

Primary Drinking Water Standards

PARAMETER	RESULTS	RANGE LOW-HIGH	MCL	MCLG	TYPICAL SOURCE
Clarity					
Turbidity (NTU) (12) (TT)	<0.6	0.05-0.10	5.0	5.0	Soil runoff
Microbiological					
Total Coliform Bacteria (18)(cfu) (<72 samples)	0 Positive	0 (72 tests)	1 pos/mo or 5%	0 pos	Naturally present in the environment
Organic Chemicals					
2,4-D (ppb)	NOT DETECTED		70	70	
Adipate (diethylhexyl) (ppb)	NOT DETECTED		400	400	
Alachlor (ppb)	NOT DETECTED		2	0	
Aldicarb (ppb)	NOT DETECTED		3	1	
Aldicarb Sulfone (ppb)	NOT DETECTED		3	1	
Aldicarb Sulfoxide (ppb)	NOT DETECTED		3	3	
Atrazine (ppb)	NOT DETECTED		5	0	
Benzene (ppb)	NOT DETECTED		200	0	
Benzo (a) Pyrene (2) (ppt)	NOT DETECTED		40	40	
Carbofuran (ppb)	NOT DETECTED		5	0	
Carbon Tetrachloride (ppb)	NOT DETECTED		2	0	
Chlordane (ppb)	NOT DETECTED		100	100	
Chlorobenzene (ppb)	NOT DETECTED		200	200	
Di (2-ethylhexyl) adipate (ppb)	NOT DETECTED		400	0	
Di (2-ethylhexyl) phthalate (PAE) (ppb)	NOT DETECTED		6	0	
Dibromochloropropane (DBCP) (2) (ppt)	NOT DETECTED		200	0	
Dichlorobenzene (p-) (ppb)	NOT DETECTED		75	75	
Dichlorobenzene o- (Ortho-) (ppb)	NOT DETECTED		600	600	
Dichloroethane (1,2-) (ppb)	NOT DETECTED		5	0	
Dichloroethylene (1,1-) (ppb)	NOT DETECTED		7	7	
Dichloroethylene (Trans-1,2-) (ppb)	NOT DETECTED		100	100	
Dichloromethane	NOT DETECTED		5	0	
Dichloropropane (1,2-) (ppb)	NOT DETECTED		5	0	
Dinoseb (ppb)	NOT DETECTED		7	7	
Dioxin (3) (ppq)	STATE WIDE WAIVER		30	0	
Diquat (4) (ppb)	STATE WIDE WAIVER		20	20	
Endothall (4) (ppb)	NOT DETECTED		100	100	
Endrin (ppb)	NOT DETECTED		2	2	
Ethylbenzene (ppb)	NOT DETECTED		700	700	
Ethylene Dibromide (EDB) (5) (ppt)	NOT DETECTED		50	0	
Glyphosate (3) (ppb)	STATE WIDE WAIVER		700	700	
Heptachlor (ppt)	NOT DETECTED		400	0	
Heptachlor Epoxide (ppt)	NOT DETECTED		200	0	
Heptachlor/Heptachlor Epoxide (ppt)	NOT DETECTED		200	0	
Hexachlorobenzene (ppb)	NOT DETECTED		1	0	
Hexachlorocyclopentadiene (ppb)	NOT DETECTED		50	50	
Lindane (ppt)	NOT DETECTED		200	200	
Methoxychlor (ppb)	NOT DETECTED		40	40	
Methyl-Tertiary-Butyl-Ether (MTBE) (13) (ppb)	NOT DETECTED		35	35	
Oxamyl (Vydate) (ppb)	NOT DETECTED		200	200	
Pentachlorophenol (ppb)	NOT DETECTED		1	0	
Picloram (ppb)	NOT DETECTED		500	500	
Polychlorinated Biphenyls (PCBs) (ppt)	NOT DETECTED		500	0	
Silvex (2,4,5-TP) (ppb)	NOT DETECTED		50	50	
Simazine (ppb)	NOT DETECTED		4	4	

PARAMETER	Test Date	RESULTS	RANGE LOW-HIGH	MCL	MCLG	TYPICAL SOURCE
Organic Chemicals (continued)						
Styrene (ppb)	5/4/2020	0.6		100	100	Discharge from rubber and plastic factories. Leaching from landfills.
Tetrachloroethylene (TCE) (ppb)	4/8/2014	NOT DETECTED		5	0	
Toluene (ppm)	6/30/2020	NOT DETECTED		1	1	
Toxaphene (ppb)	4/8/2014	NOT DETECTED		3	0	
Trichlorobenzene (1,2,4-) (ppb)	6/30/2020	NOT DETECTED		70	70	
Trichloroethane (1,1,1-) (TCA) (ppb)	6/30/2020	NOT DETECTED		200	200	
Trichloroethane (1,1,2-) (ppb)	6/30/2020	NOT DETECTED		5	3	
Trichloroethylene (TCE) (ppb)	4/8/2014	NOT DETECTED		5	0	
Vinyl Chloride (ppb)	6/30/2020	NOT DETECTED		2	0	
Xylenes (ppm)	6/30/2020	NOT DETECTED		10	10	
PFAS (19)						
25 PFAS Chemicals (ppt)	10/2021	NOT DETECTED		20		Man-made chemical from various industrial and consumer products generally designed to repel water and resist stains and grease.
Inorganic Chemicals						
Antimony, TOTAL (ppb)	3/27/2017	0.51		6	6	Discharge from petroleum refineries, fire retardants, ceramics, electronics, and solder.
Arsenic (15) (ppb)	6/10/2020	NOT DETECTED		10	0	Erosion of natural deposits.
Asbestos (1) (MFL)	7/18/2022	NOT DETECTED		7	7	
Barium (ppm)	6/10/2020	0.0043		2	2	Discharge of drilling wastes and from metal refineries. Erosion of natural deposits.
Beryllium (ppb)	6/10/2020	NOT DETECTED		4	4	
Cadmium (ppb)	6/10/2020	NOT DETECTED		5	5	
Chromium (Total) (ppb)	6/10/2020	0.55		100	100	Discharge from steel and pulp mills. Erosion of natural deposits.
Copper (7) (ppm) 0 sites failed out of 20 sampled	8/2020	0.185		AL = 1.3	1.3	Corrosion of household plumbing systems.
Cyanide (ppb)	7/11/2017	NOT DETECTED		200	200	
Fluoride (6) (ppm)	11/14/22	0.84	0.50 - 1.2	4	4	Erosion of natural deposits. Water additive which promotes strong teeth.
Lead (7) (ppb) 0 sites failed out of 20 sampled	8/2020	4.26		AL = 15	0	Discharge from fertilizer and aluminum factories.
Mercury (ppb)	6/10/2020	NOT DETECTED		2	2	Corrosion of household plumbing systems.
Nitrate (17) (ppm)	5/4/2022	0.65		10	10	Runoff from fertilizer use. Leaching from septic tanks, sewage.
Nitrite (ppm)	6/10/2020	NOT DETECTED		1	1	Erosion of natural deposits.
Selenium (ppb)	6/10/2020	NOT DETECTED		0.05	0.05	
Thallium (ppb)	6/10/2020	NOT DETECTED		0.002	0.002	
Disinfection By-Products						
Total Trihalomethanes (TTHM) (8) (ppb)	LRAA 2022	8.4	8.4-8.4	80	0	By-product of drinking water chlorination.
Total Haloacetic Acids (HAA5) (8) (ppb)	LRAA 2022	1	1 - 1	60	0	By-product of drinking water chlorination.
Radionuclides						
Radon Screen (10) (pCi/L)	6/17/2005	969		4,000	N/A	Erosion of natural deposits.
Gross Alpha Screen (9) (pCi/l)	4/27/2021	NOT DETECTED		15	0	Erosion of natural deposits.
Combined Radium (226-0.932/228-1.61) (pCi/L)	10/20/2020	2.54		5	0	Erosion of natural deposits.
Uranium-238 (16) (ppb)	4/8/2014	1.4		30	0	Erosion of natural deposits.
Combined Uranium (ppb)	4/15/2021	1		30	0	Erosion of natural deposits.
Other						
Cryptosporidium/Giardia (11)				0	0	
Calcium (mg/l)	5/4/2020	21				
Chlorine Residual (ppm)	2022	0.39	0.20 - 0.40	MRDL = 4	MRDLG = 4	By-product of drinking water chlorination.

Definitions:

Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.

Maximum Contaminant Level Goal (MCLG) established by EPA: The level of a contaminant in drinking water below which there is no known or expected risk to health.

Maximum Contaminant Level (MCL) established by EPA: The level of a contaminant in drinking water below which there is no known or expected risk to health.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in the drinking water. This is used to determine compliance.

Variance of Waiver: State or U.S. EPA permission not to meet MCL or treatment technique under certain conditions (e.g. waiver to filtration).

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water (e.g. turbidity).

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow (e.g. lead, copper).

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfection Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Concentrations: In this report, most of the quantities are expressed as ppm, ppd, ppt and pCi/L. These are a measure of organics, inorganics or radiation activity per a fixed amount of water.

Million Fibers Per Liter (MFL)

Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.

Parts per Million (ppm) or milligrams per liter (mg/L): the equivalent of one drop of chemical per every 10 gallons.

Parts per Billion (ppb) or micrograms per liter (ug/L): is the equivalent of one drop of chemical per every 10,000 gallons.

Parts per Trillion (ppt): Is the equivalent of one drop of chemical per every 10,000,000 gallons.

Parts per quadrillion (ppq): Is equivalent of one drop of chemical per every 10,000,000,000 gallons.

Picocuries per Liter (pCi/L): Is a measure of the amount of naturally occurring radiation per liter of water.

Nephelometric Turbidity Units (NTU): Turbidity Units are the measurement of cloudiness in the water.

Colony forming units: (cfu)

Positive Samples (pos)

Secondary Drinking Water Standards

PARAMETER	Test Date	RESULTS	RANGE LOW-HIGH	MCL	MCLG	TYPICAL SOURCE
Chloride	6/10/2020	8	8-12	250	250	
Magnesium	6/10/2020	2.6				
Foaming Agents (MBAS)		N/A		0.5	0.5	
Iron	6/10/2020	0.077				
Manganese	5/16/2020	0.012		0.3	0.3	
Silver	6/10/2020	NOT DETECTED		0.10	0.10	
Sulfate	6/10/2020	4		250	250	
Total Dissolved Solids		N/A		500	500	
Zinc	6/10/2020	0.0019	<0.002-0.028	2	2	
Sodium	6/10/2020	12				
Nickel	4/8/2014	0.00071				
Physical Parameters						
Color (units)	6/10/2020	< 5		50.0	50.0	
pH	5/4/2020	7.8	6.5-8.5	8.5	8.5	

Footnotes:

- (1) Asbestos - State wide waiver to testing in Maine. Only those systems with asbestos pipe need test every year, otherwise, the requirement is one test every 9 years.
- (2) Dibromochloropropane - State wide waiver granted to Maine
- (3) Dioxin/Glyphosate - State wide waiver granted to Maine
- (4) Diquat/Endothall - Testing only required if potato growing occurs in watershed.
- (5) Ethylene Dibromide - Testing only required for ground water systems. State wide waiver for surface water systems in Maine.
- (6) Fluoride - Levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm. **2022 Monthly Average- 73 ppm**
- (7) Lead/Copper: Action Levels (AL) are measured at consumer's tap. 90% of tests in water system must be equal to or below action level
- (8) TTHM & HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on running annual average.
- (9) Gross Alpha - Action level over 5 pCi/L requires testing for Radium 226/228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results=Net Gross Alpha
- (10) Radon - The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4,000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.
- (11) Cryptosporidium, Giardia, Legionella - Surface Waters Only. Ground waters not required to test or exempt before 1999.
- (12) Turbidity - Surface waters only; 1.49 NTU for Slow Sand or APT Turbidity (continued) 0.549 NTU for Conventional or Direct Filtration; 5.0 ntu for unfiltered surface water systems.
- (13) MTBE - State of Maine MCL standard, adopted in February 1998
- (14) E. Coli: E. Coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
- (15) Arsenic - While your drinking water may meet EPA's standard for Arsenic, if it contains between 5 to 10 ppb you should know that the standard balances the current understanding of arsenic's possible health effects against the costs of removing it from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. Quarterly compliance is based on running annual average.
- (16) Uranium - The U.S. EPA adopted the new MCL standard of 30 ppb, in December 2000. Water systems must meet this new standard by December 2003.
- (17) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.
- (18) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.
- (19) PFAS - The degree of risk depends on the level of chemicals and duration of exposure. Laboratory studies of animals exposed to high doses of PFAS have shown numerous negative effects such as issues with reproduction, growth, and development, thyroid function, immune system, neurology, as well as injury to the liver. Research is still relatively new, and more needs to be done to fully assess exposure effects on the human body.